

### Sample Information

Sample Name: 40x40x2.0mm Square Post

Sample Quantity: 1 pc

### Test carried out in accordance of ASTM E2358

1. Concentrated load of 200 lbf (0.89 kN) applied in any direction.
2. With 25% safety factor on the test
2. With 50% safety factor on the test



### Test Result:

Pass

**Test Item:** Concentrated load of 200 lbf (0.89 kN) applied on one post.

Concentrated load (kN)	Deflection (mm)
0.890	24.76
1.112	32.50
1.335	36.61

### Appendix: Test Pictures



Operators: